AQUA-CHECK

Water Sample Results Report
CONFIDENTIAL

Aqua-Check
1801 Hollis Street, Suite 1220
Halifax, NS, B3J 3N4
p. (902) 423-6030
p. (866) 423-6030 (Toll free)
f. (902) 423-6047

Test Name: P/A + chl res

Company: **CSAP Acadian School Board**
9248 Highway 1
Meteghan River, NS, B0W2Z0

Registration No. 2001-019388

Sample ID: AC 60020
Sample Location caretaker's tap
Sample Date: 6 Dec 2016
Sample Time: 12:40:00

Building: **École des Beaux-Marais**
5261 Highway 7
Porters Lake, NS, B3E1J7

Company Contact: **Stephane Bertrand**
p. 902-769-5463
f. 902-769-5471

Building Contact: DOE- Bedford
p. 902-424-3856
f. 902-424-0597
e.

This sample meets the health objective guidelines for Canadian Drinking Water Quality for the parameters below. (See **Exceeds** column below)

Parameter	Value	Units	Exceeds	GCDWQ Level	Health Objective
E.Coli	ABSENT	unit		n/a	MAC
Total Coliform	ABSENT	unit		n/a	MAC
Chlorine Residual	0.73	mg/L		0.199 to 4.000 mg/L	n/a

GCDWQ = Guidelines for Canadian Drinking Water Quality
MAC = Maximum Allowable Concentration IMAC = Interim Maximum Allowable Concentration AO = Aesthetic Objective

PRIVATE RESIDENCE

1. If any COLIFORMS (E.coli or Total) are present, water source should be disinfected or water boiled prior to consumption. Health Canada recommends that water contaminated with any coliforms be maintained at a rolling boil for at least 1 minutes prior to being consumed.

2. Refer to the provided information regarding suggested safety measures. After disinfection, resample at all regular sampling locations as soon as possible.

3. Contact the NS Department of Health or the NS Department of Environment for additional information, including disinfection instructions or check their website (http://www.gov.ns.ca/nse/water/privatewells.asp).

NSDE REGISTERED PUBLIC DRINKING WATER SOURCES

1. Owners of Registered public drinking water supplies are required to immediately report positive results to their local Department of Environment (NSDE) office. If the local office cannot be reached, the NSDE Environmental toll free number is 1-877-936-8476. Registed public drinking water sources are also required to resample withing 24-hours of receiving notification of presence of any coliforms and forward results immediately to NSDE.

2. If any COLIFORMS (E.coli or Total) are present initiate a BOIL WATER ADVISORY. Health Canada recommends that water contaminated with any coliforms be maintained at a rolling boil for at least 1 minutes prior to being consumed.

3. Contact the NS Department of Health or the NS Department of Environment for additional information, including disinfection instructions or check their website (http://www.gov.ns.ca/nse/).

----------END OF REPORT----------