Water Sample Results Report
CONFIDENTIAL

Aqua-Check
1801 Hollis Street, Suite 1220
Halifax, NS, B3J 3N4
p. (902) 423-6030
p. (866) 423-6030 (Toll free)
f. (902) 423-6047

Test Name: P/A + chl res

Company: **CSAP Acadian School Board**
9248 Highway 1
Meteghan River, NS, B0W2Z0

Registration No.

Sample ID: AC 54699
Sample Location staffroom tap
Sample Date: 10 Dec 2015
Sample Time: 11:45:00

Building: **École du Carrefour**
201A Portage Bay
Dartmouth, NS, B2X3T4

Company Contact: **Stephane Bertrand**
p. 902-769-5463
f. 902-769-5471

Building Contact: DOE- Bedford
p. 902-424-3856
f. 902-424-0597
e.

This sample meets the health objective guidelines for Canadian Drinking Water Quality for the parameters below. (See **Exceeds** column below)

Parameter	Value	Units	Exceeds	GCDWQ Level	Health Objective
E.Coli	ABSENT	unit		n/a	MAC
Total Coliform	ABSENT	unit		n/a	MAC
Chlorine Residual	0.5	mg/L		0.199 to 4.000 mg/L	n/a

GCDWQ = Guidelines for Canadian Drinking Water Quality
MAC = Maximum Allowable Concentration IMAC = Interim Maximum Allowable Concentration AO = Aesthetic Objective

PRIVATE RESIDENCE

1. If any COLIFORMS (E.coli or Total) are present, water source should be disinfected or water boiled prior to consumption. Health Canada recommends that water contaminated with any coliforms be maintained at a rolling boil for at least 1 minutes prior to being consumed.

2. Refer to the provided information regarding suggested safety measures. After disinfection, resample at all regular sampling locations as soon as possible.

3. Contact the NS Department of Health or the NS Department of Environment for additional information, including disinfection instructions or check their website (http://www.gov.ns.ca/nse/water/privatewells.asp).

NSDE REGISTERED PUBLIC DRINKING WATER SOURCES

1. Owners of Registered public drinking water supplies are required to immediately report positive results to their local Department of Environment (NSDE) office. If the local office cannot be reached, the NSDE Environmental toll free number is 1-877-936-8476. Registed public drinking water sources are also required to resample withing 24-hours of receiving notification of presence of any coliforms and forward results immediately to NSDE.

2. If any COLIFORMS (E.coli or Total) are present initiate a BOIL WATER ADVISORY. Health Canada recommends that water contaminated with any coliforms be maintained at a rolling boil for at least 1 minutes prior to being consumed.

3. Contact the NS Department of Health or the NS Department of Environment for additional information, including disinfection instructions or check their website (http://www.gov.ns.ca/nse/).

----------END OF REPORT----------

Maxxam Job #: B5P4621
Report Date: 2015/12/11

Aqua-Check Inc

MICROBIOLOGY COLILERT (DRINKING WATER)

Maxxam ID		BMT870
Sampling Date		2015/12/10 11:45
COC Number		193120
Registration #		
	UNITS	**AC54699**
Microbiological		
Escherichia coli	P-A/100mL	ND
Total Coliforms	P-A/100mL	ND
ND = Not detected		

Maxxam Analytics International Corporation o/a Maxxam Analytics 200 Bluewater Rd, Suite 105, Bedford, Nova Scotia Canada B4B 1G9 Tel: 902-420-0203 Toll-free: 800-565-7227 Fax: 902-420-8612 www.maxxamanalytics.com