



Water Sample Results Report
CONFIDENTIAL

Aqua-Check
1801 Hollis Street, Suite 1220
Halifax, NS, B3J 3N4
p. (902) 423-6030
p. (866) 423-6030 (Toll free)
f. (902) 423-6047

Company: CSAP Acadian School Board
9248 NS-1
Meteghan River, Nova Scotia, B0W2Z0

Company Contact: Stephane Bertrand
p. 902-769-5463
f. 902-769-5471

Building Contact: Mathieu Haley
p. 9022240862
f. 902-563-2387

Building: Centre Scolaire Étoile de l'Acadie
15 Inglis Street
Sydney, Nova Scotia, B1P7C6

Test Name: P/A

Sample ID: AC B16030
Sample Location: Staff Lunchroom Tap
Sample Date: 21 Sep 2020
Sample Time: 12:51:04

Registration No. N/A

Latitude: 46.140939
Longitude: -60.181713

DOE Contact: DOE- Sydney
p.
f. 902-563-2387

This sample meets the health objective guidelines for Canadian Drinking Water Quality for the parameters below. (See Exceeds column below)

| Parameter | Value | Units | Exceeds | GCDWQ Level | Health Objective |
|----------------|-------|-------|---------|-------------|------------------|
| E Coli | ND | p/a | No | n/a | MAC |
| Total Coliform | ND | p/a | No | n/a | MAC |

GCDWQ = Guidelines for Canadian Drinking Water Quality

MAC = Maximum Allowable Concentration, IMAC = Interim Maximum Allowable Concentration, AO = Aesthetic Objective

PRIVATE RESIDENCE

1. If any COLIFORMS (E.coli or Total) are present, water source should be disinfected or water boiled prior to consumption. Health Canada recommends that water contaminated with any coliforms be maintained at a rolling boil for at least 1 minutes prior to being consumed.
2. Refer to the provided information regarding suggested safety measures. After disinfection, resample at all regular sampling locations as soon as possible.
3. Contact the NS Department of Health or the NS Department of Environment for additional information, including disinfection instructions or check their website (<http://www.gov.ns.ca/nse/water/privatewells.asp>).

NSDE REGISTERED PUBLIC DRINKING WATER SOURCES

1. Owners of Registered public drinking water supplies are required to immediately report positive results to their local Department of Environment (NSDE) office. If the local office cannot be reached, the NSDE Environmental toll free number is 1-877-936-8476. Registered public drinking water sources are also required to resample within 24-hours of receiving notification of presence of any coliforms and forward results immediately to NSDE.
2. If any COLIFORMS (E.coli or Total) are present initiate a BOIL WATER ADVISORY. Health Canada recommends that water contaminated with any coliforms be maintained at a rolling boil for at least 1 minutes prior to being consumed.
3. Contact the NS Department of Health or the NS Department of Environment for additional information, including disinfection instructions or check their website (<http://www.gov.ns.ca/nse/>).

-----END OF REPORT-----