



Water Sample Results Report  
CONFIDENTIAL

Aqua-Check  
1801 Hollis Street, Suite 1220  
Halifax, NS, B3J 3N4  
p. (902) 423-6030  
p. (866) 423-6030 (Toll free)  
f. (902) 423-6047

**Building:** École Secondaire de Clare  
80 Placide Comeau Road  
Meteghan River, Nova Scotia, B0W2L0

**Test Name:** P/A

**Company:** CSAP Acadian School Board  
9248 NS-1  
Meteghan River, Nova Scotia, B0W2Z0

**Sample ID:** AC B15321  
**Sample Location:** Kitchen Tap  
**Sample Date:** 04 Jun 2020  
**Sample Time:** 09:18:28

**Company Contact:** Stephane Bertrand  
p. 902-769-5463  
f. 902-769-5471

**Registration No.** 2001-018795

**Latitude:** 44.226411  
**Longitude:** -66.131397

**Building Contact:** Mathieu Haley  
p. 9022240862  
f. 902-742-7796

**DOE Contact:** DOE-Yarmouth  
p.  
f. 902-742-7796

This sample meets the health objective guidelines for Canadian Drinking Water Quality for the parameters below. (See Exceeds column below)

Parameter	Value	Units	Exceeds	GCDWQ Level	Health Objective
E Coli	ABSENT	p/a	No	n/a	MAC
Total Coliform	ABSENT	p/a	No	n/a	MAC

GCDWQ = Guidelines for Canadian Drinking Water Quality  
MAC = Maximum Allowable Concentration, IMAC = Interim Maximum Allowable Concentration, AO = Aesthetic Objective

PRIVATE RESIDENCE

1. If any COLIFORMS (E.coli or Total) are present, water source should be disinfected or water boiled prior to consumption. Health Canada recommends that water contaminated with any coliforms be maintained at a rolling boil for at least 1 minutes prior to being consumed.
2. Refer to the provided information regarding suggested safety measures. After disinfection, resample at all regular sampling locations as soon as possible.
3. Contact the NS Department of Health or the NS Department of Environment for additional information, including disinfection instructions or check their website (<http://www.gov.ns.ca/nse/water/privatewells.asp>).

NSDE REGISTERED PUBLIC DRINKING WATER SOURCES

1. Owners of Registered public drinking water supplies are required to immediately report positive results to their local Department of Environment (NSDE) office. If the local office cannot be reached, the NSDE Environmental toll free number is 1-877-936-8476. Registered public drinking water sources are also required to resample within 24-hours of receiving notification of presence of any coliforms and forward results immediately to NSDE.
2. If any COLIFORMS (E.coli or Total) are present initiate a BOIL WATER ADVISORY. Health Canada recommends that water contaminated with any coliforms be maintained at a rolling boil for at least 1 minutes prior to being consumed.
3. Contact the NS Department of Health or the NS Department of Environment for additional information, including disinfection instructions or check their website (<http://www.gov.ns.ca/nse/>).

-----END OF REPORT-----