



Water Sample Results Report CONFIDENTIAL

Aqua-Check

1801 Hollis Street, Suite 1220
Halifax, NS, B3J 3N4
p. (902) 423-6030
p. (866) 423-6030 (Toll free)
f. (902) 423-6047

Building: **École Jean Marie Gay**
9680 Route 1
Saulnierville, NS, B0W2Z0

Test Name: P/A
Company: **CSAP Acadian School Board**
9248 Highway 1
Meteghan River, NS, B0W2Z0
Registration No. 2001-01826
Sample ID: AC 210174
Sample Location kitchen tap
Sample Date: 11 Dec 2017
Sample Time: 12:51:00
Company Contact: **Stephane Bertrand**
p. 902-769-5463
f. 902-769-5471
Building Contact: DOE- Yarmouth
p. 902-742-8985
f. 902-742-7796
e.

This sample meets the health objective guidelines for Canadian Drinking Water Quality for the parameters below. (See **Exceeds** column below)

Parameter	Value	Units	Exceeds	GCDWQ Level	Health Objective
E Coli	ABSENT	p/a	No		MAC
Total Coliform	ABSENT	p/a	No		MAC

GCDWQ = Guidelines for Canadian Drinking Water Quality

MAC = Maximum Allowable Concentration, IMAC = Interim Maximum Allowable Concentration, AO = Aesthetic Objective

PRIVATE RESIDENCE

1. If any COLIFORMS (E.coli or Total) are present, water source should be disinfected or water boiled prior to consumption. Health Canada recommends that water contaminated with any coliforms be maintained at a rolling boil for at least 1 minutes prior to being consumed.
2. Refer to the provided information regarding suggested safety measures. After disinfection, resample at all regular sampling locations as soon as possible.
3. Contact the NS Department of Health or the NS Department of Environment for additional information, including disinfection instructions or check their website (<http://www.gov.ns.ca/nse/water/privatewells.asp>).

NSDE REGISTERED PUBLIC DRINKING WATER SOURCES

1. Owners of Registered public drinking water supplies are required to immediately report positive results to their local Department of Environment (NSDE) office. If the local office cannot be reached, the NSDE Environmental toll free number is 1-877-936-8476. Registered public drinking water sources are also required to resample within 24-hours of receiving notification of presence of any coliforms and forward results immediately to NSDE.
2. If any COLIFORMS (E.coli or Total) are present initiate a BOIL WATER ADVISORY. Health Canada recommends that water contaminated with any coliforms be maintained at a rolling boil for at least 1 minutes prior to being consumed.
3. Contact the NS Department of Health or the NS Department of Environment for additional information, including disinfection instructions or check their website (<http://www.gov.ns.ca/nse/>).

-----END OF REPORT-----